



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 149

Customer

Facility Name: Hilton Garden Inn
Address: Synergy Dr.
Uniontown, PA 15401

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 7/21/25
Time: 1:05 PM
Method: Grab

Sample Final Analysis

Date: 7/24/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/22/25 11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25 11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25 5:30 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/22/25 12:30 PM	AH	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	7/21/25 1:05 PM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25 1:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25 1:05 PM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 149

Customer

Facility Name: Hilton Garden Inn
Address: Synergy Dr.
Uniontown, PA 15401

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 7/21/25
Time: 1:05 PM
Method: Grab

Sample Final Analysis

Date: 7/24/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/22/25	12:30 PM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	1:05 PM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	1:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	1:05 PM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor