



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*  
  
**Address:** *810 Highland Meadow Dr.*  
*Washington, PA 15301*

**Matrix:** *Recreational Water*

**Source Type:** *Spa*

**Sample Collection**

**Date:** *10/13/25*  
**Time:** *10:54 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *10/16/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |                  |    |          |
|-------------------|--------|--------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 10/14/25 9:00 AM | JC | SM 9222G |
|-------------------|--------|--------|------------------|----|----------|

|                  |          |          |                  |    |          |
|------------------|----------|----------|------------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 10/14/25 9:00 AM | JC | SM 9222B |
|------------------|----------|----------|------------------|----|----------|

|                       |      |        |                  |    |          |
|-----------------------|------|--------|------------------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 10/13/25 3:20 PM | SL | SM 9215B |
|-----------------------|------|--------|------------------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |                           |    |          |
|---------------------|----------|----------|---------------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 10/14/25 Total coliforms: | SL | SM 9230C |
|---------------------|----------|----------|---------------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |                   |    |     |
|-----|--------|--------------|-------------------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 10/13/25 10:54 AM | GR | DPD |
|-----|--------|--------------|-------------------|----|-----|

|           |          |                |                   |    |     |
|-----------|----------|----------------|-------------------|----|-----|
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 10/13/25 10:54 AM | GR | DPD |
|-----------|----------|----------------|-------------------|----|-----|

|            |       |           |                   |    |        |
|------------|-------|-----------|-------------------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/13/25 10:54 AM | GR | Visual |
|------------|-------|-----------|-------------------|----|--------|

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor