



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 434**

**Customer**

**Facility Name:** SRU Field House  
**Address:** 101 Field House Rd.  
Slippery Rock, PA 16057  
**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 9/29/25  
**Time:** 2:30 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 10/2/25  
**Time:** 11:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/30/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/30/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/29/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/29/25	2:30 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/29/25	2:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/29/25	2:30 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor