Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# **2454**

Customer		*Sample Collection*	
Facility Name:	Rosedale Beach	*Date:*	7/7/25
		Time:	11:00 AM
Address:	5407 3rd St.	*Method:*	Grab
	Verona, PA 15147		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	7/10/25
		Time:	9:30 AM
Source Type:	Baby Pool	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	11:00 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	11:00 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	11:00 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	Rosedale Beach		*Date:*	7/7/25
			Time:	11:00 AM
Address:	5407 3rd St.		*Method:*	Grab
	Verona, PA 15147			
			Sample Final Analysis	
Matrix:	Recreational Water		*Date:*	7/10/25
			Time:	9:30 AM
Source Type:	Baby Pool		*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	11:00 AM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	11:00 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	11:00 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor