Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# **2587**

Customer

		Sample Collection	
Facility Name:	Wilson Pool (Greentree Borough)	*Date:*	6/4/25
		Time:	10:20 AM
Address:	825 Poplar Street	*Method:*	Grab
	Pittsburgh, PA 15220		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	6/6/25
		Time:	4:00 PM
Source Type:	Deep End	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/4/25	10:20 AM	DW	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/4/25	10:20 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	10:20 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2587

Customer

			Sample Collection	
Facility Name:	*Wilson Pool (Greentree Borough)*		*Date:*	*6/4/25*
			Time:	10:20 AM
Address:	*825 Poplar Street*		*Method:*	*Grab*
	Pittsburgh, PA 15220			

Sample Final Analysis

		Date:	6/6/25
Matrix:	*Recreational Water*	Time:	4:00 PM
Source Type:	*Deep End*	Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/4/25	10:20 AM	DW	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/4/25	10:20 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	10:20 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor