



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2043**

**Customer**

Facility Name: Blackridge Swim Club

Address: 1200 Beulah Rd  
Pittsburgh, PA 15221

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/2/25

Time: 12:50 PM

Method: Grab

**Sample Final Analysis**

Date: 6/5/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	12:50 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	12:50 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	12:50 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2043**

**Customer**

Facility Name: *Blackridge Swim Club*

Address: *1200 Beulah Rd*  
*Pittsburgh, PA 15221*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/2/25*

Time: *12:50 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *6/5/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	12:50 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	12:50 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	12:50 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor