



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-16

Lab# 2584

**Customer**

Facility Name: Wildwood Golf Club

Address: 2195 Sample Road  
Allison Park, PA 15101

Matrix: Recreational Water

Source Type: Baby Pool

**Sample Collection**

Date: 7/14/25

Time: 9:17 AM

Method: Grab

**Sample Final Analysis**

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	AH
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	AH
Standard plate count:	0/ml	200/ml	7/14/25	3:43 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	9:17 AM	GR
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	9:17 AM	GR
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	9:17 AM	GR

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-16

Lab# 2584

**Customer**

Facility Name: Wildwood Golf Club

Address: 2195 Sample Road  
Allison Park, PA 15101

Matrix: Recreational Water

Source Type: Baby Pool

**Sample Collection**

Date: 7/14/25

Time: 9:17 AM

Method: Grab

**Sample Final Analysis**

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	AH
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	AH
Standard plate count:	0/ml	200/ml	7/14/25	3:43 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	9:17 AM	GR
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	9:17 AM	GR
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	9:17 AM	GR

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor