



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 128

Customer

Facility Name: Hampton Inn & Suites North Huntington

Address: 8441 Country Club Drive
North Huntingdon, PA 15642

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/22/25

Time: 8:31 AM

Method: Grab

Sample Final Analysis

Date: 7/25/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25 10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25 10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25 4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/22/25 8:31 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25 8:31 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25 8:31 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 128

Customer

Facility Name: Hampton Inn & Suites North Huntington

Address: 8441 Country Club Drive
North Huntingdon, PA 15642

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/22/25

Time: 8:31 AM

Method: Grab

Sample Final Analysis

Date: 7/25/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/22/25	8:31 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	8:31 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	8:31 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor