



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2172

Customer

Facility Name: *Edgeworth Club*
Address: *511 East Drive*
Sewickley, PA 15143

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/6/25*
Time: *12:45 PM*
Method: *Grab*

Sample Final Analysis

Date: *8/8/25*
Time: *2:00 PM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/6/25 | 4:50 PM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/6/25 | 4:50 PM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/6/25 | 3:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/6/25 | 12:45 PM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/6/25 | 12:45 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/6/25 | 12:45 PM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2172

Customer

Facility Name: Edgeworth Club
Address: 511 East Drive
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/6/25
Time: 12:45 PM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 2:00 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/6/25 | 4:50 PM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/6/25 | 4:50 PM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/6/25 | 3:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/6/25 | 12:45 PM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/6/25 | 12:45 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/6/25 | 12:45 PM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor