

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2309

Customer				Sample Collection			
Facility Name:	Koa Campground			Date:	7/15/25		
				Time:	9:18 AM		
Address: 7 Koa Road,				Method:	Grab		
	Washington, PA 15301						
Martinian	Recreational Water			Sample Final Analysis			
Matrix:	Recreational	vvater	Date: Time:		7/18/25 9:30 AM		
Source Type:	Pool			Analyst:	9.30 AN AS		
Source Type:	POOI			Allalyst.	AS		
Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/16/25	10:10 AM	EB	SM 9222G	
Total coliforms:	100/100mls	2/100mls	7/16/25	10:10 AM	EB	SM 9222B	
Standard plate count:	5700/ml	200/ml	7/15/25	4:00 PM	АН	SM 9215B	
Field Analysis	Results	Reporting limit	D	ate/Time	Analyst	Method	
- 101u / 111u.j 010					7		
рН:	7.4 SU	7.2 - 7.8 SU	7/15/25	9:18 AM	GR	DPD	
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	9:18 AM	GR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	9:18 AM	GR	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2309

Customer				Sample Collection			
Facility Name:	Koa Campground			Date:	7/15/25		
				Time:	9:18 AM		
Address: 7 Koa Road,				Method:	Grab		
	Washington, PA 15301						
Martinian	Recreational Water			Sample Final Analysis			
Matrix:	Recreational	vvater	Date: Time:		7/18/25 9:30 AM		
Source Type:	Pool			Analyst:	9.30 AN AS		
Source Type:	POOI			Allalyst.	AS		
Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/16/25	10:10 AM	EB	SM 9222G	
Total coliforms:	100/100mls	2/100mls	7/16/25	10:10 AM	EB	SM 9222B	
Standard plate count:	5700/ml	200/ml	7/15/25	4:00 PM	АН	SM 9215B	
Field Analysis	Results	Reporting limit	D	ate/Time	Analyst	Method	
- 101u / 111u.j 010					7		
рН:	7.4 SU	7.2 - 7.8 SU	7/15/25	9:18 AM	GR	DPD	
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	9:18 AM	GR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	9:18 AM	GR	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith