



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2013**

**Customer**

Facility Name: *Alcoma on the Green*

Address: *225 Alcoma Blvd.*  
*Penn Hills, PA 15235*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/30/25*

Time: *10:10 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/3/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/30/25	10:10 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:10 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:10 AM	EH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2013**

**Customer**

Facility Name: *Alcoma on the Green*

Address: *225 Alcoma Blvd.*  
*Penn Hills, PA 15235*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/30/25*

Time: *10:10 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/3/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/30/25	10:10 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:10 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:10 AM	EH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor