



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2333

Customer

Facility Name: *Majestic Hills*
Address: *1010 Forest Lane Dr.*
Cannonsburg, PA 15317

Sample Collection

Date: *5/28/25*
Time: *12:45 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *5/31/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 10:05 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 10:05 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 5:36 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|-----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 5/28/25 | 12:45 PM | AF | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 12:45 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 12:45 PM | AF | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2333

Customer

Facility Name: *Majestic Hills*
Address: *1010 Forest Lane Dr.*
Cannonsburg, PA 15317

Sample Collection

Date: *5/28/25*
Time: *12:45 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *5/31/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 10:05 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 10:05 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 5:36 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|-----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 5/28/25 | 12:45 PM | AF | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 12:45 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 12:45 PM | AF | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor