



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2081

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 8/11/25
Time: 1:30 PM
Method: Grab

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

Facility Name:

Carriage Park Apt.

Address:

300 Chatham Park Dr.
Pittsburgh, PA 15220

Matrix:

Recreational Water

Source Type:

Deep End

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/12/25 | 11:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/12/25 | 11:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/11/25 | 6:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/11/25 | 1:30 PM | CW | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/11/25 | 1:30 PM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/11/25 | 1:30 PM | CW | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2081

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Carriage Park Apt.

Date: 8/11/25

Address: 300 Chatham Park Dr.
Pittsburgh, PA 15220

Time: 1:30 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/14/25

Source Type: Deep End

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/12/25 | 11:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/12/25 | 11:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/11/25 | 6:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/11/25 | 1:30 PM | CW | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/11/25 | 1:30 PM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/11/25 | 1:30 PM | CW | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor