



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 019

Customer

Facility Name: *Baxter Building*

Address: *925 Brushton Ave
Pittsburgh, PA 15208*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *6/3/25*

Time: *8:50 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/6/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	6/4/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	6/4/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	A	6/3/25	5:15 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	6/3/25	8:50 AM	DW	DPD
Chlorine:	5.0 mg/l	D	6/3/25	8:50 AM	DW	DPD
Turbidity:	1 NTU	A	6/3/25	8:50 AM	DW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 019

Customer

Facility Name: *Baxter Building*

Address: *925 Brushton Ave*
Pittsburgh, PA 15208

Sample Collection

Date: *6/3/25*
Time: *8:50 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Final Analysis

Date: *6/6/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	6/4/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	6/4/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	A	6/3/25	5:15 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	6/3/25	8:50 AM	DW	DPD
Chlorine:	5.0 mg/l	D	6/3/25	8:50 AM	DW	DPD
Turbidity:	1 NTU	A	6/3/25	8:50 AM	DW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor