



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2545

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Valleybrook Swim Club

Sample Collection

Date: 6/2/25

Address: 100 Callender Rd
Pittsburgh, PA 15237

Time: 8:56 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/5/25

Source Type: Baby Pool

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/3/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	8:56 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/2/25	8:56 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	8:56 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2545

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Valleybrook Swim Club

Sample Collection

Date: 6/2/25

Address: 100 Callender Rd
Pittsburgh, PA 15237

Time: 8:56 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/5/25

Source Type: Baby Pool

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/3/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	8:56 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/2/25	8:56 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	8:56 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor