

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 261

Customer

Facility Name: *Rehabilitation Institute*

Address: *1405 Shady Ave.
Pittsburgh, PA 15217*

Matrix: *Recreational Water*

Source Type: *Pool - Lg*

Sample Collection

Date: *8/4/25*

Time: *9:10 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/7/25*

Time: *11:20 AM*

Analyst: *AS*


| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/5/25 9:50 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 9:50 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/4/25 3:15 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|----------------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/4/25 9:10 AM | LM | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 9:10 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 9:10 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 261

Customer

Facility Name: *Rehabilitation Institute*

Address: *1405 Shady Ave.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Pool - Lg*

Sample Collection

Date: *8/4/25*
Time: *9:10 AM*
Method: *Grab*

Sample Final Analysis

Date: *8/7/25*
Time: *11:20 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/5/25 9:50 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 9:50 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/4/25 3:15 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|----------------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/4/25 9:10 AM | LM | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 9:10 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 9:10 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith