



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2004

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 8/20/25
Time: 1:39 PM
Method: Grab

Sample Final Analysis

Date: 8/22/25
Time: 3:30 PM
Analyst: AS

Facility Name: Accord -Avonworth
Address: 498 Camp Horne Road
Pittsburgh, PA 15237

Matrix: Recreational Water
Source Type: Deep End

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|---------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 8/20/25 | 5:45 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/20/25 | 5:45 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/20/25 | 5:45 PM | AS | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 8.0 SU | 7.2 - 7.8 SU | 8/20/25 | 1:39 PM | MM | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 8/20/25 | 1:39 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/20/25 | 1:39 PM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor