



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*

**Address:** *810 Highland Meadow Dr.  
Washington, PA 15301*

**Matrix:** *Recreational Water*

**Source Type:** *Spa*

**Sample Collection**

**Date:** *9/22/25*

**Time:** *10:45 AM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *9/25/25*

**Time:** *10:00 AM*

**Analyst:** *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |         |         |    |          |
|-------------------|--------|--------|---------|---------|----|----------|
| Escherichia Coli: | Absent | Absent | 9/23/25 | 9:30 AM | JC | SM 9222G |
|-------------------|--------|--------|---------|---------|----|----------|

|                  |          |          |         |         |    |          |
|------------------|----------|----------|---------|---------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 9/23/25 | 9:30 AM | JC | SM 9222B |
|------------------|----------|----------|---------|---------|----|----------|

|                       |      |        |         |         |    |          |
|-----------------------|------|--------|---------|---------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 9/22/25 | 3:00 PM | SL | SM 9215B |
|-----------------------|------|--------|---------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |         |                  |    |          |
|---------------------|----------|----------|---------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 9/23/25 | Total coliforms: | JC | SM 9230C |
|---------------------|----------|----------|---------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |         |          |    |     |
|-----|--------|--------------|---------|----------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 9/22/25 | 10:45 AM | GR | DPD |
|-----|--------|--------------|---------|----------|----|-----|

|           |          |                |         |          |    |     |
|-----------|----------|----------------|---------|----------|----|-----|
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 9/22/25 | 10:45 AM | GR | DPD |
|-----------|----------|----------------|---------|----------|----|-----|

|            |       |           |         |          |    |        |
|------------|-------|-----------|---------|----------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/22/25 | 10:45 AM | GR | Visual |
|------------|-------|-----------|---------|----------|----|--------|

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor