



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 154**

**Customer**

**Facility Name:** Hilton Garden Inn  
**Address:** 2000 Garden View Ln.  
Cranberry, PA 16066

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 6/17/25  
**Time:** 11:06 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/20/25  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/18/25              | 10:30 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/18/25              | 10:30 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/17/25              | 5:00 PM  | AH      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 6/18/25              | 11:30 AM | EB      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 6/17/25   | 11:06 AM | ZR      | DPD    |
| Chlorine:      | 1.0 mg/l | 1.0 - 5.0 mg/l  | 6/17/25   | 11:06 AM | ZR      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/17/25   | 11:06 AM | ZR      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 154**

**Customer**

**Facility Name:** Hilton Garden Inn  
**Address:** 2000 Garden View Ln.  
Cranberry, PA 16066

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 6/17/25  
**Time:** 11:06 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/20/25  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/18/25              | 10:30 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/18/25              | 10:30 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/17/25              | 5:00 PM  | AH      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 6/18/25              | 11:30 AM | EB      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 6/17/25   | 11:06 AM | ZR      | DPD    |
| Chlorine:      | 1.0 mg/l | 1.0 - 5.0 mg/l  | 6/17/25   | 11:06 AM | ZR      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/17/25   | 11:06 AM | ZR      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor