



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-11**

**Lab# 2321**

**Customer**

**Facility Name:** *Liberty Pointe*  
**Address:** *35 Highland Rd.*  
*Bethel Park, PA 15102*

**Sample Collection**

**Date:** *7/8/25*  
**Time:** *9:01 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/11/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	180/ml	200/ml	7/8/25	3:48 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.9 SU	7.2 - 7.8 SU	7/8/25	9:01 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	9:01 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:01 AM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-11**

**Lab# 2321**

**Customer**

**Facility Name:** *Liberty Pointe*  
**Address:** *35 Highland Rd.*  
*Bethel Park, PA 15102*

**Sample Collection**

**Date:** *7/8/25*  
**Time:** *9:01 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/11/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	180/ml	200/ml	7/8/25	3:48 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.9 SU	7.2 - 7.8 SU	7/8/25	9:01 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	9:01 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:01 AM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor