

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: The View@North Hills

Address: 1000 Johanna Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 5/28/25

 Time:
 11:11 AM

 Method:
 Grab

Sample Final Analysis

 Date:
 5/31/25

 Time:
 9:30 AM

 Analyst:
 AS

Accredited Analysis	Results R	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	5/29/25	11:30 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	5/29/25	11:30 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:11 AM	MM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:11 AM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:11 AM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: The View@North Hills

Address: 1000 Johanna Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 5/28/25

 Time:
 11:11 AM

 Method:
 Grab

Sample Final Analysis

 Date:
 5/31/25

 Time:
 9:30 AM

 Analyst:
 AS

Accredited Analysis	Results R	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	5/29/25	11:30 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	5/29/25	11:30 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:11 AM	MM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:11 AM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:11 AM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor