



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2062

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Brook Park Swim Club

Date: 6/4/25

Time: 5:00 PM

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/6/25

Time: 4:00 PM

Source Type: Deep End

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25 6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25 6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/4/25 5:00 PM	SL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/4/25 5:00 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25 5:00 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2062

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Brook Park Swim Club

Date: 6/4/25

Time: 5:00 PM

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/6/25

Time: 4:00 PM

Source Type: Deep End

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25 6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25 6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/4/25 5:00 PM	SL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/4/25 5:00 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25 5:00 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor