



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2106**

**Customer**                      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*                      *City View*

*Address:*                              *1420 Centre Ave*  
Pittsburgh, PA 15219

*Matrix:*                                *Recreational Water*

*Source Type:*                        *Pool*

**Sample Collection**

*Date:*                                      *8/5/25*  
*Time:*                                    *10:45 AM*  
*Method:*                                *Grab*

**Sample Final Analysis**

*Date:*                                      *8/8/25*  
*Time:*                                    *8:30 AM*  
*Analyst:*                                *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	10:45 AM	LM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	10:45 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	10:45 AM	LM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor

