



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 232

Customer

Facility Name: Moon Area High School

Address: 8353 University Blvd.
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 1/5/26

Time: 9:26 AM

Method: Grab

Sample Final Analysis

Date: 1/8/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/6/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/6/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/5/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/5/26	9:26 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/5/26	9:26 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/5/26	9:26 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)