



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2432**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Reserve at Southpoint*  
  
*Address:*            *1000 Meadow Lane*  
                              *Canonsburg PA 15317*

**Sample Collection**

*Date:*                  8/19/25  
*Time:*                2:01 PM  
*Method:*            Grab

*Matrix:*              *Recreational Water*  
  
*Source Type:*      *Pool*

**Sample Final Analysis**

*Date:*                  8/22/25  
*Time:*                9:00 AM  
*Analyst:*             AS

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	8/20/25      11:15 AM	SL	SM 9222G

Total coliforms:	0/100mls	2/100mls	8/20/25      11:15 AM	SL	SM 9222B
------------------	----------	----------	-----------------------	----	----------

Standard plate count:	0/ml	200/ml	8/19/25      5:20 PM	SL	SM 9215B
-----------------------	------	--------	----------------------	----	----------

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
Fecal Streptococcus	0/100mls	2/100mls	1/0/00      12:00 AM	0	SM 9230C

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
pH:	7.8 SU	7.2 - 7.8 SU	8/19/25      2:01 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/19/25      2:01 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25      2:01 PM	AF	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor