



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 411

Laboratory Analysis Report

Customer

Facility Name: Fairfield Inn Airport
Address: 1004 Sutherland Dr
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 1/12/26
Time: 12:00 PM
Method: Grab

Sample Final Analysis

Date: 1/15/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	1/13/26 9:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/13/26 9:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/12/26 4:45 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	1/13/26 12:00 PM	JC	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	1/12/26 12:00 PM	VH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	1/12/26 12:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/12/26 12:00 PM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)