



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2064

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Brook Park Swim Club

Date: 7/21/25

Time: 11:11 AM

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/24/25

Time: 10:00 AM

Source Type: Wading Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25	11:11 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	11:11 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	11:11 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2064

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Brook Park Swim Club

Date: 7/21/25

Address: 8190 Rochester Rd
Pittsburgh, PA 15237

Time: 11:11 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/24/25

Source Type: Wading Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/21/25	11:11 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	11:11 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	11:11 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor