



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 133

Customer

Facility Name: Hampton Inn - Uniontown

Address: 698 West Main Street
Uniontown, PA 15401

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/22/25

Time: 1:20 PM

Method: Grab

Sample Final Analysis

Date: 12/25/25

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Escherichia Coli:	Absent	Absent	12/23/25	11:00 AM	JC	SM 9222G
-------------------	--------	--------	----------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	12/23/25	11:00 AM	JC	SM 9222B
------------------	----------	----------	----------	----------	----	----------

Standard plate count:	0/ml	200/ml	12/22/25	5:20 PM	AS	SM 9215B
-----------------------	------	--------	----------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Non-accredited

Fecal Streptococcus	0/100mls	2/100mls	12/23/25	1:00 PM	JC	SM 9230C
---------------------	----------	----------	----------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.8 SU	7.2 - 7.8 SU	12/22/25	1:20 PM	SH	DPD
-----	--------	--------------	----------	---------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/22/25	1:20 PM	SH	DPD
-----------	----------	----------------	----------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	12/22/25	1:20 PM	SH	Visual
------------	-------	-----------	----------	---------	----	--------

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)