



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2279**

**Customer**

**Facility Name:** *Hunting Ridge*  
**Address:** *401 Meeting House Rd.*  
*Bridgeville, PA 15017*

**Matrix:** *Recreational Water*

**Source Type:** *Baby Pool*

**Sample Collection**

**Date:** *6/24/25*  
**Time:** *2:52 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/27/25*  
**Time:** *9:20 AM*  
**Analyst:** *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/25/25              | 12:00 PM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/25/25              | 12:00 PM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/24/25              | 5:40 PM  | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/24/25   | 2:52 PM | AF      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 6/24/25   | 2:52 PM | AF      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/24/25   | 2:52 PM | AF      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2279**

**Customer**

**Facility Name:** *Hunting Ridge*  
**Address:** *401 Meeting House Rd.*  
*Bridgeville, PA 15017*

**Matrix:** *Recreational Water*

**Source Type:** *Baby Pool*

**Sample Collection**

**Date:** *6/24/25*  
**Time:** *2:52 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/27/25*  
**Time:** *9:20 AM*  
**Analyst:** *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/25/25              | 12:00 PM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/25/25              | 12:00 PM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/24/25              | 5:40 PM  | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/24/25   | 2:52 PM | AF      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 6/24/25   | 2:52 PM | AF      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/24/25   | 2:52 PM | AF      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor