Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2234

Customer		_Sample Collection_	
Facility Name:	_Green Oaks C.C._	_Date:_	_8/5/25_
		Time:	1:40 PM
Address:	_5741 3rd Street_	_Method:_	_Grab_
	Verona, PA 15147		
		Sample Final Analysis	
Matrix:	_Recreational Water_	_Date:_	_8/8/25_
		Time:	8:30 AM
Source Type:	_Shallow End_	_Analyst:_	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/5/25	1:40 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:40 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:40 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2234

B & R Pools and Swim Shop

Customer

Facility Name:	*Green Oaks C.C.*
Address:	*5741 3rd Street*
	Verona, PA 15147
Matrix:	*Recreational Water*
Source Type:	*Shallow End*

Sample Collection

Date:	*8/5/25*
Time:	1:40 PM
Method:	*Grab*

Sample Final Analysis

Date:	*8/8/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/5/25	1:40 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:40 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:40 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor