



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2082

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Carriage Park Apt.*

Date: *6/9/25*

Address: *300 Chatham Park Dr.*
Pittsburgh, PA 15220

Time: *1:30 PM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *6/12/25*

Source Type: *Shallow End*

Time: *9:30 AM*

Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	11:55 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	11:55 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	1:30 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	1:30 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	1:30 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2082

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Carriage Park Apt.
Address: 300 Chatham Park Dr.
Pittsburgh, PA 15220

Date: 6/9/25
Time: 1:30 PM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Shallow End

Date: 6/12/25
Time: 9:30 AM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	11:55 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	11:55 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	1:30 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	1:30 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	1:30 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor