Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2171

Customer

			Sample Collection	
Facility Name:	*Edgewood Club*		*Date:*	*7/7/25*
			Time:	2:13 PM
Address:	*1 Pennwood Ave*		*Method:*	*Grab*
	Pittsburgh, PA 15218			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/10/25*
			Time:	*9:30 AM*
Source Type:	*Baby Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	190/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	2:13 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	2:13 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	2:13 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2171

Customer

Facility Name:	Edgewood Club
Address:	1 Pennwood Ave
	Pittsburgh, PA 15218
Matrix:	Recreational Water
Source Type:	Baby Pool

Sample Collection

Date:	7/7/25
Time:	2:13 PM
Method:	Grab

Sample Final Analysis

Date:	7/10/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	190/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	2:13 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	2:13 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	2:13 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor