Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2173

B & R Pools and Swim Shop

Customer

Facility Name:	Edgeworth Club
Address:	511 East Drive Sewickley, PA 15143
Matrix:	Recreational Water
Source Type:	Baby Pool

Sample Collection

Date:	6/18/25
Time:	12:45 PM
Method:	Grab

Sample Final Analysis

Date:	6/20/25
Time:	3:30 PM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	4:05 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	4:05 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/18/25	4:05 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/18/25	12:45 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/18/25	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/18/25	12:45 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith
Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2173

Customer

Facility Name:	*Edgeworth Club*
Address:	*511 East Drive*
	Sewickley, PA 15143
Matrix:	*Recreational Water*
Source Type:	*Baby Pool*

Sample Collection

Date:	*6/18/25*
Time:	12:45 PM
Method:	*Grab*

Sample Final Analysis

Date:	*6/20/25*
Time:	*3:30 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	4:05 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	4:05 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/18/25	4:05 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/18/25	12:45 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/18/25	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/18/25	12:45 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith
Andre Smith, Lead Supervisor