



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2154**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Evalee*      *Date:*      *6/17/25*  
*Address:*      *7 Dorchester Dr.*      *Time:*      *3:32 PM*  
*Pittsburgh, PA 15241*      *Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*      *Date:*      *6/20/25*  
*Source Type:*      *Pool*      *Time:*      *9:00 AM*  
*Analyst:*      *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:35 AM	AH	SM 9222B
Standard plate count:	200/ml	200/ml	6/17/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	3:32 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	3:32 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	3:32 PM	SL	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2154**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Evalee*      *Date:*      *6/17/25*  
*Address:*      *7 Dorchester Dr.*      *Time:*      *3:32 PM*  
*Pittsburgh, PA 15241*      *Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*      *Date:*      *6/20/25*  
*Source Type:*      *Pool*      *Time:*      *9:00 AM*  
*Analyst:*      *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:35 AM	AH	SM 9222B
Standard plate count:	200/ml	200/ml	6/17/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	3:32 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/17/25	3:32 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	3:32 PM	SL	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor