



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 164

Customer

Facility Name: *Holiday Inn Express - Butler*

Address: *203 North Duffy Rd
Butler, PA 16001*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *1/5/26*

Time: *3:05 PM*

Method: *Grab*

Sample Final Analysis

Date: *1/8/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/6/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/6/26	10:30 AM	JC	SM 9222B
Standard plate count:	70/ml	200/ml	1/5/26	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/5/26	3:05 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	1/5/26	3:05 PM	BH	DPD
Turbidity:	2 NTU	1 - 2 NTU	1/5/26	3:05 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor