



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 322**

**Customer**

**Facility Name:** Upper St. Clair Rec.  
**Address:** 1551 Mayview Road  
Upper St. Clair, PA 15241

**Sample Collection**

**Date:** 10/15/25  
**Time:** 2:34 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 10/17/25  
**Time:** 6:00 PM  
**Analyst:** AS

**Matrix:** Recreational Water

**Source Type:** Spa

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Escherichia Coli:	Absent	Absent	10/15/25	5:40 PM	SL	SM 9222G
-------------------	--------	--------	----------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	10/15/25	5:40 PM	SL	SM 9222B
------------------	----------	----------	----------	---------	----	----------

Standard plate count:	0/ml	200/ml	10/15/25	5:20 PM	AS	SM 9215B
-----------------------	------	--------	----------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	10/15/25	5:40 PM	AS	SM 9213C
---------------------	----------	----------	----------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	10/15/25	2:34 PM	MM	DPD
-----	--------	--------------	----------	---------	----	-----

Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	10/15/25	2:34 PM	MM	DPD
-----------	----------	----------------	----------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	10/15/25	2:34 PM	MM	Visual
------------	-------	-----------	----------	---------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor