



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 392**

**Customer**

Facility Name: YMCA Spencer Family

Address: 305 Church Rd  
Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 9/23/25

Time: 2:01 PM

Method: Grab

**Sample Final Analysis**

Date: 9/26/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/25	10:20 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/25	10:20 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/23/25	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	9/23/25	2:01 PM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/23/25	2:01 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/23/25	2:01 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor