Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# **385**

Customer

Facility Name:	*Residence Inn Forbes*
Address:	*3341 Forbes Ave*
	Pittsburgh, PA 15213
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/30/25*
Time:	11:05 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/3/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25	11:05 AM	LM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25	11:05 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	11:05 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab#   385

Customer		**Sample Collection**	
Facility Name:	*Residence Inn Forbes*	*Date:*	*6/30/25*
		Time:	11:05 AM
Address:	*3341 Forbes Ave*	*Method:*	*Grab*
	Pittsburgh, PA 15213		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/3/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25	11:05 AM	LM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25	11:05 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	11:05 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor