



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2423

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Presidential Arms

Date: 6/16/25

Address: 9815 Presidential Dr.
Allison Park, PA 15101

Time: 9:41 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/19/25

Source Type: Pool

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 10:05 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 | 10:05 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/16/25 | 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 6/16/25 | 9:41 AM | GR | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 9:41 AM | GR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 9:41 AM | GR | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2423

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Presidential Arms

Date: 6/16/25

Address: 9815 Presidential Dr.
Allison Park, PA 15101

Time: 9:41 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/19/25

Source Type: Pool

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 10:05 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 | 10:05 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/16/25 | 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 6/16/25 | 9:41 AM | GR | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 9:41 AM | GR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 9:41 AM | GR | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor