



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2249

Customer

Facility Name: *Hickory Hills Apts*

Address: *100 Arthur Drive*
Wexford, PA 15090

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/29/25*
Time: *12:26 PM*
Method: *Grab*

Sample Final Analysis

Date: *8/1/25*
Time: *9:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/30/25 10:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 10:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/29/25 12:26 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/29/25 12:26 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 12:26 PM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2249

Customer

Facility Name: *Hickory Hills Apts*

Address: *100 Arthur Drive*
Wexford, PA 15090

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/29/25*
Time: *12:26 PM*
Method: *Grab*

Sample Final Analysis

Date: *8/1/25*
Time: *9:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/30/25 10:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 10:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 4:00 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/29/25 12:26 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/29/25 12:26 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 12:26 PM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor