

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

Laboratory Analysis Report

C-10

Lab# 261

Customer

Rehabilitation Institute

Facility Name: Address:

1405 Shady Ave.

Pittsburgh, PA 15217

Matrix:

Recreational Water

Source Type:

Pool - Lg

Sample Collection

Date:

8/4/25 9:10 AM

Time: Method:

Grab

Sample Final Analysis

Date:

8/7/25

Time:

11:20 AM

Analyst:

AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/5/25 | 9:50 AM | АН | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 | 9:50 AM | АН | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/4/25 | 3:15 PM | АН | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | _ |
|----------------|----------|-----------------|-----------|---------|---------|--------|---|
| рН: | 7.4 SU | 7.2 - 7.8 SU | 8/4/25 | 9:10 AM | LM | DPD | |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 | 9:10 AM | LM | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 | 9:10 AM | LM | Visual | |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

Laboratory Analysis Report

C-10

Lab# 261

Customer

Rehabilitation Institute

Facility Name: Address:

1405 Shady Ave.

Pittsburgh, PA 15217

Matrix:

Recreational Water

Source Type:

Pool - Lg

Sample Collection

Date:

8/4/25 9:10 AM

Time: Method:

Grab

Sample Final Analysis

Date:

8/7/25

Time:

11:20 AM

Analyst:

AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/5/25 | 9:50 AM | АН | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/5/25 | 9:50 AM | АН | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/4/25 | 3:15 PM | АН | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | _ |
|----------------|----------|-----------------|-----------|---------|---------|--------|---|
| рН: | 7.4 SU | 7.2 - 7.8 SU | 8/4/25 | 9:10 AM | LM | DPD | |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 | 9:10 AM | LM | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 | 9:10 AM | LM | Visual | |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith