



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2734

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Highland Village	Date:	6/11/25
Address:	1502 Highland Dr, Finleyville, PA 15332	Time:	3:00 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<u>Sample Final Analysis</u>	
Matrix:	Recreational Water	Date:	6/13/25
Source Type:	Pool	Time:	3:00 PM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 5:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 5:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25 4:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25 3:00 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25 3:00 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25 3:00 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2734

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		<u>Sample Collection</u>	
Facility Name:	Highland Village	Date:	6/11/25
Address:	1502 Highland Dr, Finleyville, PA 15332	Time:	3:00 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<u>Sample Final Analysis</u>	
Matrix:	Recreational Water	Date:	6/13/25
Source Type:	Pool	Time:	3:00 PM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 5:30 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 5:30 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25 4:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/11/25 3:00 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25 3:00 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25 3:00 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor