



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2167

Customer

Facility Name: Edgewood C.C.

Address: 100 Churchill Road
Pittsburgh, PA 15235

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/30/25

Time: 10:32 AM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	10:32 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:32 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:32 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2167

Customer

Facility Name: Edgewood C.C.

Address: 100 Churchill Road
Pittsburgh, PA 15235

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/30/25

Time: 10:32 AM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	10:32 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	10:32 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:32 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor