



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service**Lab# 312****Customer****Facility Name:** UPMC Lemieux Sports Complex**Address:** 8000 Cranberry Springs Drive
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Cold Plunge**Sample Collection****Date:** 12/3/24**Time:** 9:00 AM**Method:** Grab**Sample Final Analysis****Date:** 12/6/24**Time:** 9:00 AM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	190/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	NA	7.2 - 7.8 SU	12/3/24	9:00 AM	JP	DPD
Chlorine:	NA	1.0 - 5.0 mg/l	12/3/24	9:00 AM	JP	DPD
Turbidity:	NA	1 - 2 NTU	12/3/24	9:00 AM	JP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service**Lab# 312****Customer****Facility Name:** UPMC Lemieux Sports Complex**Address:** 8000 Cranberry Springs Drive
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Cold Plunge**Sample Collection****Date:** 12/3/24**Time:** 9:00 AM**Method:** Grab**Sample Final Analysis****Date:** 12/6/24**Time:** 9:00 AM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	190/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	NA	7.2 - 7.8 SU	12/3/24	9:00 AM	JP	DPD
Chlorine:	NA	1.0 - 5.0 mg/l	12/3/24	9:00 AM	JP	DPD
Turbidity:	NA	1 - 2 NTU	12/3/24	9:00 AM	JP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor