1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 290

Customer

Facility Name:	*Springhill Suites*
Address:	*16 Trinity Point Drive*
	Washington, PA 15301
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*5/28/25*
Time:	11:27 AM
Method:	*Grab*

Sample Final Analysis

Date:	*5/31/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	5/28/25	11:27 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:27 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:27 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 290

Customer

Facility Name:	*Springhill Suites*
Address:	*16 Trinity Point Drive*
	Washington, PA 15301
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*5/28/25*
Time:	11:27 AM
Method:	*Grab*

Sample Final Analysis

Date:	*5/31/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	5/28/25	11:27 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:27 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:27 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor