



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2050

Customer

Facility Name: Bower Hill Apt III
Address: 1170 Bower Hill Road
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/23/25
Time: 10:46 AM
Method: Grab

Sample Final Analysis

Date: 6/26/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/24/25 | 10:40 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/24/25 | 10:40 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/23/25 | 6:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/23/25 | 10:46 AM | CW | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/23/25 | 10:46 AM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/23/25 | 10:46 AM | CW | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2050

Customer

Facility Name: Bower Hill Apt III
Address: 1170 Bower Hill Road
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/23/25
Time: 10:46 AM
Method: Grab

Sample Final Analysis

Date: 6/26/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/24/25 | 10:40 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/24/25 | 10:40 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/23/25 | 6:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/23/25 | 10:46 AM | CW | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/23/25 | 10:46 AM | CW | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/23/25 | 10:46 AM | CW | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor