



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 386

Customer

Facility Name: *Residence Inn Cranberry*

Address: *1308 Freedom Rd.
Cranberry, PA 16066*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/14/25*

Time: *11:12 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/17/25*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:53 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	11:12 AM	ZR	DPD
Chlorine:	8.0 mg/l	1.0 - 5.0 mg/l	7/14/25	11:12 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:12 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 386

Customer

Facility Name: *Residence Inn Cranberry*

Address: *1308 Freedom Rd.
Cranberry, PA 16066*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/14/25*

Time: *11:12 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/17/25*

Time: *8:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:53 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	11:12 AM	ZR	DPD
Chlorine:	8.0 mg/l	1.0 - 5.0 mg/l	7/14/25	11:12 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	11:12 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)