



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041
Service

Lab# 380

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	PPG Paints Arena	Date:	2/2/26			
Address:	1001 Fifth Ave Pittsburgh, PA 15219	Time:	11:15 AM			
Matrix:		Method:	Grab			
Source Type:	Recreational Water	Date:	2/5/26			
	Therapy Spa	Time:	10:30 AM			
		Analyst:	AS			
<u>Accredited Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Incubation Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
Escherichia Coli:	Absent	Absent	2/3/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/3/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/2/26	4:10 PM	SL	SM 9215B
<u>Additional Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Incubation Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
Fecal Streptococcus	0/100mls	2/100mls	2/3/26	11:00 AM	JC	SM 9230C
<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.4 SU	7.2 - 7.8 SU	2/2/26	11:15 AM	AG	DPD
Chlorine:	4.8 mg/l	1.0 - 5.0 mg/l	2/2/26	11:15 AM	AG	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/2/26	11:15 AM	AG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)