



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2355

Customer

Facility Name: Montclair Estates
Address: 1200 Sherbrook Drive
Pittsburgh, PA 15241
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 6/2/25
Time: 11:08 AM
Method: Grab

Sample Final Analysis

Date: 6/5/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|--------|
| Escherichia Coli: | Absent | Absent | 6/3/25 | 10:30 AM | AH |
| Total coliforms: | 0/100mls | 2/100mls | 6/3/25 | 10:30 AM | AH |
| Standard plate count: | 0/ml | 200/ml | 6/2/25 | 5:40 PM | SL |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/2/25 | 11:08 AM | AF |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/2/25 | 11:08 AM | AF |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/2/25 | 11:08 AM | AF |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2355

Customer

Facility Name: Montclair Estates
Address: 1200 Sherbrook Drive
Pittsburgh, PA 15241
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 6/2/25
Time: 11:08 AM
Method: Grab

Sample Final Analysis

Date: 6/5/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|--------|
| Escherichia Coli: | Absent | Absent | 6/3/25 | 10:30 AM | AH |
| Total coliforms: | 0/100mls | 2/100mls | 6/3/25 | 10:30 AM | AH |
| Standard plate count: | 0/ml | 200/ml | 6/2/25 | 5:40 PM | SL |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/2/25 | 11:08 AM | AF |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/2/25 | 11:08 AM | AF |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/2/25 | 11:08 AM | AF |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith