



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2372

Customer

Facility Name: *Newport Square*
Address: *520 Newport Drive
Pittsburgh, PA 15235*
Matrix: *Recreational Water*
Source Type: *Pool*

Sample Collection

Date: *7/7/25*
Time: *10:20 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/10/25*
Time: *9:30 AM*
Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	10:20 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/25	10:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	10:20 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2372

Customer

Facility Name: *Newport Square*

Address: *520 Newport Drive
Pittsburgh, PA 15235*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/7/25*

Time: *10:20 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	10:20 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/25	10:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	10:20 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor